


D1146T G-DRIVE

OPOWER RATING

Engine Speed rev/min	Type of Operation	Engine Power	
		kWm	Ps
1800	Continuous Power	113	153
	Prime Power	125	170
	Standby Power	138	187
1500	Continuous Power	97	131
	Prime Power	107	145
	Standby Power	118	160



Note: -. The engine performance corresponds to ISO 3046, BS 5514 and DIN 6271.

- -. Ratings are based on ISO 8528.
 - → **Prime power** available at variable load. The permissible average power out put (during 24h period) shell not exceed 70% of the prime power rating.
 - ightarrow **Standby power** available in the event of a main power network failure. No overload is permitted.

\odot	ME	CHA	NICAL	SYS	LEM

© FUEL CONSUMPTION

○ Engine Model	D1146T	• Prime Power (lit/hr)	1,500 rpm	1,800 rpm
○ Engine Type	In-line 4 cycle, water cooled	25%	8.2	11.4
	Turbo charged	50%	13.6	18.1
○ Combustion type	Direct injection	75%	19.5	24.9
○ Cylinder Type	Replaceable dry liner	100%	25.9	32.5
 Number of cylinders 	6	○ Standby Power (lit/h	1,500 rpm	1,800 rpm
○ Bore x stroke	111(4.37) x 139(5.47) mm(in.)	25%	8.6	11.9
○ Displacement	8.071(492.49) lit.(in ³)	50%	14.3	19.6
○ Compression ratio	16.8:1	75%	20.4	27.3
○ Firing order	1-5-3-6-2-4	100%	27.0	35.1
○ Injection timing	11° BTDC			
 Compression pressure 	Above 28 kg/cm2(398 psi) at 200rpm	© FUEL SYSTEM		
Ory weight	Approx. 780 kg (1,720 lb)	○ Injection pump	Zexel in-line "A	.D" type
○ Dimension	1,277 x 824 x 1,074 mm	○ Governor	RSV type (all s	peed control)
(LxWxH)	(50.3 x 32.4 x 42.3 in.)	○ Feed pump	Mechanical type	e
○ Rotation	Counter clockwise viewed from Flywheel	○ Injection nozzle	Multi hole type	
○ Fly wheel housing	SAE NO.2	Opening pressure	214 kg/cm ² (3,0	44 psi)
○ Fly wheel	Clutch NO.11 1/2	○ Fuel filter	Full flow, cartri	dge type
		○ Used fuel	Diesel fuel oil	

© MECHANISM

© LUBRICATION SYSTEM

○ Type	Over head valve		 Lub. Method 	Fully forced pressure feed type
O Number of valve	Intake 1, exhaust 1	per cylinder	○ Oil pump	Gear type driven by crankshaft
O Valve lashes at cold	Intake 0.30mm (0.	0118 in.)	○ Oil filter	Full flow, cartridge type
	Exhaust 0.30mm (0	.0118 in.)	Oil pan capacity	High level 15.5 liters (4.09 gal.)
				Low level 12 liters (3.17 gal.)
© VALVE TIMING			 Angularity limit 	Front down 25 deg.
	Opening	Close		Front up 25 deg.
O Intake valve	16 deg. BTDC	36 deg. ABDC		Side to side 25 deg.
○ Exhaust valve	46 deg. BBDC	14 deg. ATDC	○ Lub. Oil	Refer to Operation Manual



D1146T G-DRIVE

© COOLING SYSTEM

O Cooling method Fresh water forced circulation

• Water capacity 14 liters (3.70 gal.)

(engine only)

OPressure system Max. 0.9 kg/cm² (12.8 psi)

Centrifugal type driven by belt ○ Water pump

○ Water pump Capacity 150 liters (39.6 gal.)/min

at 1,800 rpm (engine)

○ Thermostat Wax – pellet type

Opening temp. 71°C

Full open temp. 85°C

Blower type, steel Ocooling fan

590 mm diameter, 6 blade

© ENGINEERING DATA

OWater flow 130 liters/min @1,500 rpm

150 liters/min @1,800 rpm

• Heat rejection to coolant 17.4 kcal/sec @1,800 rpm

○ Air flow 6.7 m³/min @1,500 rpm

10.6 m³/min @1,800 rpm

○ Exhaust gas flow 25.7 m³/min @1,800 rpm

470 °C @1,800 rpm • Exhaust gas temp.

○ Max. permissible restrictions

 $220 \text{ mmH}_2\text{O}$ initial -.Intake system

635 mmH₂O final

600 mmH₂O max. -.Exhaust system

© ELECTRICAL SYSTEM

• Charging generator 24V x 45A [or 12V x 26A] Aalternator

Built-in type IC regulator ○ Voltage regulator

24V x 4.5kW [or 12V x 2.5kW] ○ Starting motor

OBattery Voltage 24V [or 12V]

100 AH [or 150 AH] (recommended) O Battery Capacity


Block heater ○ Starting aid (Option)


♦ CONVERSION TABLE

 $lb/ft = N.m \times 0.737$ in. $= mm \times 0.0394$ $PS = kW \times 1.3596$ U.S. gal = lit. $\times 0.264$ kW = 0.2388 kcal/s $psi = kg/cm2 \times 14.2233$

 $lb/PS.h = g/kW.h \times 0.00162$ in3 = lit. x 61.02 $hp = PS \times 0.98635$ $cfm = m^3/min \times 35.336$

 $1b = kg \times 2.20462$





Head office

7-11, Hwasu-Dong, Dong-Gu, Incheon, Korea

TEL: 82-32-760-1437, 1964 FAX: 82-32-760-1964 Seoul Office

Doosan Infracore Co. Ltd.,

22nd Floor, Doosan Tower, 18-12, Euljiro 6-ga, Jung-gu,

Seoul, Korea.

TEL: 82-2-3398-8521~8535 FAX: 82-2-3398-8509 Web site: www.doosaninfracore.com

* Speccifications are subject to change without prior notice